



REQUIREMENTS FOR A BUSINESS TAX RECEIPT FIRE INSPECTION

- 1. Business must be set up as if ready to open.**
- 2. Required fire extinguisher(s) tagged by a fire extinguisher company:
Minimum size: 2A10BC
One fire extinguisher for every 2,500 square feet.
One fire extinguisher for every 50 feet of travel distance (for every exit/entrance).**
- 3. If you have illuminated exit/emergency lights, they must be working normally and on battery backup.**
- 4. Address should be on all doors.**
- 5. There should be four to five feet of aisle space minimum to all egress doors.**
- 6. Carpet "specs" indicating the "radiant flux" or "class" per the National Fire Protection Association (NFPA 253). This is required for new carpeting only.**
- 7. Other requirements may be necessary based on occupancy type.**

Please call (954) 746-3470 with any questions or to arrange a fire inspection appointment.